



ਦਫਤਰ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਪ੍ਰਾਂਤਕ ਉਪ ਮੰਡਲ ਤ ਤੇ ਮ ਸ਼ਾਖਾ, ਸੰਗਰੂਰ

ਦੂਜੀ ਮੰਜਿਲ ਬਲਾਕ-2, ਜਿਲ੍ਹਾ ਪ੍ਰਬੰਧਕੀ ਕੰਪਲੈਕਸ ਸੰਗਰੂਰ।

ਟੈਲੀਫੋਨ/ਫੈਕਸ ਨੰਬਰ. 01672-234114

EMAIL:-sdeprovincialsangrur@gmail.com



ਵੱਲ

ਪ੍ਰਿੰਸੀਪਲ,

ਸਤਿਆ ਭਾਰਤੀ ਆਦਰਸ਼ ਸੀਨੀ.ਸੈਕੰ. ਸਕੂਲ,

ਝਨੇੜੀ, ਸੰਗਰੂਰ।

ਨੰ: 41

ਮਿਤੀ:- 21/04/2026

ਵਿਸ਼ਾ: ਸਾਲ 2026-27 ਦੇ ਲਈ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਸਬੰਧੀ।

ਹਵਾਲਾ:- ਆਪ ਦਾ ਪੱਤਰ ਨੰ. SBASS/135/26-27 ਮਿਤੀ 02.04.2026 ਵੱਲ ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ, ਪ੍ਰਾਂਤਕ ਮੰਡਲ, ਲੋਕ ਨਿਰਮਾਣ ਵਿਭਾਗ ਤ ਤੇ ਮ ਸ਼ਾਖਾ, ਸੰਗਰੂਰ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਸਬੰਧੀ ਹਵਾਲਾ ਅਧੀਨ ਪੱਤਰ ਰਾਹੀਂ ਆਪ ਵੱਲੋਂ ਸਾਲ 2026-27 ਲਈ ਸਕੂਲ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਦੀ ਮੰਗ ਕੀਤੀ ਗਈ ਹੈ। ਜਿਸ ਦੇ ਸਬੰਧ ਵਿੱਚ ਪ੍ਰਾਪਤ ਹੋਏ ਕੇਸ ਅਨੁਸਾਰ ਲੋੜੀਂਦੀ ਇੰਸਪੈਕਸ਼ਨ ਕੀਤੀ ਗਈ ਅਤੇ ਇੰਸਪੈਕਸ਼ਨ ਕਰਨ ਉਪਰੰਤ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਆਪ ਨੂੰ ਅਗਲੇਰੀ ਯੋਗ ਕਾਰਵਾਈ ਹਿੱਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ। ਲੋੜੀਂਦੀ ਇੰਸਪੈਕਸ਼ਨ ਫੀਸ ਬਾਬਤ ਰੁਪਏ 10,000/- ਈ-ਚਲਾਨ ਨੰ. 22957395 ਰਾਹੀਂ ਆਪ ਦੁਆਰਾ ਡੀ.ਡੀ.ਓ. ਕੋਡ 0604 ਹੈੱਡ 8782-00-102-01-00 ਵਿੱਚ ਜਮ੍ਹਾਂ ਕਰਵਾ ਦਿੱਤੀ ਗਈ ਹੈ।

ਇਸ ਤੋਂ ਇਲਾਵਾ ਆਪ ਵੱਲੋਂ ਨਾਲ ਨੱਥੀ ਕੀਤਾ ਗਿਆ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ, ਜਿਸ ਦੀ ਜਾਰੀ ਕਰਨ ਦੀ ਮਿਤੀ 19.05.2025 ਹੈ, ਦੇ ਸਬੰਧ ਵਿੱਚ ਲਿਖਿਆ ਜਾਂਦਾ ਹੈ ਕਿ ਉਕਤ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਦੀ ਮਿਆਦ 31.03.2027 ਤੱਕ ਵਧਾਉਣ ਦੀ ਜ਼ਿੰਮੇਵਾਰੀ ਆਪ ਦੀ ਨਿੱਜੀ ਹੋਵੇਗੀ ਅਤੇ ਮਿਆਦ ਵਧਾਉਣ ਉਪਰੰਤ ਇਸ ਦਫਤਰ ਨੂੰ ਸੂਚਿਤ ਕੀਤਾ ਜਾਵੇ ਅਜਿਹਾ ਨਾ ਕਰਨ ਦੀ ਸੂਰਤ ਵਿੱਚ ਇਸ ਦਫਤਰ ਵੱਲੋਂ ਜਾਰੀ ਕੀਤਾ ਗਿਆ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਮਿਤੀ 18.05.2026 ਤੋਂ ਬਾਅਦ ਰੱਦ ਸਮਝਿਆ ਜਾਵੇਗਾ।

ਨੱਥੀ/ਸਰਟੀਫਿਕੇਟ

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ

ਪ੍ਰਾਂਤਕ ਉਪ ਮੰਡਲ, ਲੋ.ਨਿ.ਵਿ

ਤ ਤੇ ਮ ਸ਼ਾਖਾ, ਸੰਗਰੂਰ।

ਪਿੱਠ ਅੰਕਣ ਨੰ.

ਮਿਤੀ:-

ਉਪਰੋਕਤ ਦਾ ਉਤਾਰਾ ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ, ਪ੍ਰਾਂਤਕ ਮੰਡਲ, ਲੋਕ ਨਿਰਮਾਣ ਵਿਭਾਗ ਤ ਤੇ ਮ ਸ਼ਾਖਾ, ਸੰਗਰੂਰ ਨੂੰ ਉਨ੍ਹਾਂ ਦੇ ਪਿੱਠ ਅੰਕਣ ਨੰ. 370 ਮਿਤੀ 13-04-2026 ਦੇ ਸਬੰਧ ਵਿੱਚ ਸੂਚਨਾ ਹਿੱਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ ਜੀ।

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ

ਪ੍ਰਾਂਤਕ ਉਪ ਮੰਡਲ, ਲੋ.ਨਿ.ਵਿ

ਤ ਤੇ ਮ ਸ਼ਾਖਾ, ਸੰਗਰੂਰ।





Building Safety Report

Name of School :- Satya Bharti Adarsh Sr. Sec. School,
Jhaneri, Sangrur

I have visited the above-mentioned school Building along with Sh. Sahil Garg, Junior Engineer and on his visually inspection, it seems visually safe subject to the following observations and conditions:-

- a) Parameters to check the stability and safety of building as Architectural Drawings, Bearing capacity, Foundation detail, Structural Drawings, Technical Specifications, Test Reports of Material used, Quality Control reports and certificate from the Engineer in-Charge for construction are not available.
- b) In case any addition, alteration or expansion and modification to this building are done certificate may be obtained after the completion from the undersigned.
- c) In case the building is affected by flood or if there is any settlement of walls/ foundation or sagging of roofs etc. immediate inspection of the undersigned be arranged to check stability and safety of the building.
- d) A separate certificate regarding Fire Fighting should be obtained from the competent Authority.
- e) A separate certificate regarding Electrical works should be obtained from the competent Authority.
- f) The owner of the building / Management is fully responsible regarding safety of the building from all angles in spite of the report.
- g) The covered area of the building as per Drawings is 48500.00 Sq.ft
- h) The report is not valid for legal purpose.
- i) The building visually seems safe to occupy for normal use to **One Year, upto 31/03/2027**
- j) This Building Safety Certificate should not be considered as NOC for Road Access which will be taken separately by the School as per Government Policy No. 5/13/018-3BR3/1294287/3 Dated: 10.08.2018.
- k) It is hereby stated in reference to the Fire Safety Certificate attached by you, which was issued on 19.05.2025, that the responsibility of getting the validity of the said Fire Safety Certificate extended till 31.03.2027 shall lie solely with you. After extending the validity, this office must be informed accordingly. Failing to do so, the Building Safety Certificate issued by this office shall be deemed cancelled after 18.05.2026


Junior Engineer


Sub Divisional Engineer
Provincial Sub Division
PWD B&R, Sangrur